



**Questions and Answers in reference to:
National School District
24-25-12B Warehouse Accessibility**

Page 1 of 1

Question #1 What is the paving section that we are to propose?

Answer: Specification section 32 12 16 Asphalt Paving makes repeated reference to meeting CalTrans standards. Section to be as follows: 12" scarified and compacted native material subgrade, 6" Class II base, 3" AC pavement – all to meet CalTrans standards and specifications. Refer to specification for more information. Details in drawing set to be updated for final DSA submittal.

Specification section 32 13 13 Concrete Paving covers the construction and standards for the concrete paving work. Concrete paving thickness to be 4". Details in drawing set to be updated for final DSA submittal.